



902 Redwood Drive, Loveland, CO 80538 (888) 371-2145

| | | |
|--|---|--|
| REPORTING ADDRESS: MicroTrack\Bluelight 902 Redwood Drive Loveland, CO 80538 | INSPECTION ADDRESS: MicroTrack\Bluelight 961 Pottstown Pike Chester Springs, PA 19425 | CUSTOMER # 80 CONTRACT # 80 CONTACT: Bill Brown PHONE: FAX: INSPECTOR(S): Jim Brown INSPECTION DATE: 08/02/2001 |
|--|---|--|

FIRE EXTINGUISHER INSPECTION

ANSWER KEY: If question was asked about more than one of the same device, the answer includes brackets. [Number in bracket] = quantity of item inspected. Refer to discrepancies section of report for footnotes shown after brackets. --- indicates that this question is either not applicable or not due for this device.

FIRE EXTINGUISHERS

Report shows the status of extinguishers at this site after inspection has been finished.

| EXTINGUISHER TYPE | SERIAL NUMBER | MONTHLY INSP. | ANNUAL INSP. | REPLACED FOR 6 YEAR MAINT.? | LAST HYDRO DATE | REPLACED FOR HYDRO? |
|---|---------------|---------------|--------------|-----------------------------|-----------------|---------------------|
| FL01 CHEMICAL PUMP STATION (TOWER) | | | | | | |
| CARBON DIOXIDE | T-00723421 | Pass | Pass | ---- | 05/23/2002 | Yes |
| CARBON DIOXIDE | V-191870 | Pass | Pass | ---- | 05/23/2002 | Yes |
| FL01 BY THE OFFICE | | | | | | |
| DRY CHEM - STORED PRESSURE- REFILLABLE | KT-413701 | Pass | Pass | Yes | 05/23/2002 | Yes |
| FL01 SOUTH EXIT DOOR | | | | | | |
| CARBON DIOXIDE | W-895553 | Pass | Pass | ---- | 05/23/2002 | Yes |
| FL01 NORTH OVERHEAD DOORS | | | | | | |
| CARBON DIOXIDE | W-895554 | Pass | Pass | ---- | 05/23/2002 | Yes |
| FL01 COOLING TOWER BY BRANCH VALVE | | | | | | |
| CARBON DIOXIDE | U-814937 | Pass | Pass | ---- | 05/23/2002 | Yes |
| FL02 SOUTH EAST ELECTRICAL ROOM | | | | | | |
| CARBON DIOXIDE | W-895560 | Pass | Pass | ---- | 05/23/2002 | Yes |
| FL02 SOUTH WEST ELECTRICAL ROOM | | | | | | |
| CARBON DIOXIDE | W-895551 | Pass | Pass | ---- | 05/23/2002 | Yes |

DISCREPANCIES

CARBON DIOXIDE

Area: FL01 Location: CHEMICAL PUMP STATION (TOWER)

1
Q# 01 - Hydrostatic test due. Did you remove from service and replace?
ExtWO What did you do with the old extinguisher? = REPAIR REPLACE

Area: FL01 Location: CHEMICAL PUMP STATION (TOWER)

2
Q# 01 - Hydrostatic test due. Did you remove from service and replace?
ExtWO What did you do with the old extinguisher? = REPAIR REPLACE

Area: FL01 Location: SOUTH EXIT DOOR

3
Q# 01 - Hydrostatic test due. Did you remove from service and replace?
ExtWO#02155002 What did you do with the old extinguisher? = REPLACED EXTINGUISHER

Area: FL01 Location: NORTH OVERHEAD DOORS

4
Q# 01 - Hydrostatic test due. Did you remove from service and replace?
ExtWO#02155002 What did you do with the old extinguisher? = REPLACED EXTINGUISHER

Area: FL01 Location: COOLING TOWER BY BRANCH VALVE

5
Q# 01 - Hydrostatic test due. Did you remove from service and replace?
Reason for not Inspecting = Needs Hydro.

REPAIR REPLACE

Area: FL02 Location: SOUTH EAST ELECTRICAL ROOM

6
Q# 01 - Hydrostatic test due. Did you remove from service and replace?
ExtWO#02155002 What did you do with the old extinguisher? = FIXED DURING INSPECTION

Area: FL02 Location: SOUTH WEST ELECTRICAL ROOM

7
Q# 01 - Hydrostatic test due. Did you remove from service and replace?
ExtWO#02155002 What did you do with the old extinguisher? = FIXED DURING INSPECTION

DRY CHEM - STORED PRESSURE- REFILLABLE

Area: FL01 Location: BY THE OFFICE

8
Q# 01 - Hydrostatic test due. Did you remove from service and replace?
ExtWO#02155002 What did you do with the old extinguisher? = REPLACED EXTINGUISHER

9
Q# 02 - Six-year maintenance due. Did you remove from service and replace?
Reason for not Inspecting = Needs Hydro.

REPAIR REPLACE

Comments:

The owner and/or designated representative acknowledges the responsibility of the operating condition of the component parts at the time of this inspection. It is agreed that the inspection service provided by the contractor as prescribed herein is limited to performing a visual inspection and/or routine testing, and any investigation or unscheduled testing, modification, maintenance, repair, etc., of the component parts is not included as part of the inspection work performed. It is further understood that all information contained herein is provided to the best of the knowledge of the party providing such information.

Inspector's Signature: X _____
Inspector's Name: BILL BROWN

Customer's Signature: X _____
Customer's Name: JIM BROWN